Arkansas State Mandated Inspections Public Schools

| RESPONSIBLE PARTY | SYSTEM | FREQUENCY | CODE SECTION OR REGULATION |
|---------------------------|--|---|--|
| PUBLIC SCHOOL | Fire Extinguishers | Monthly | AFPC, Vol. 1, Section 906.2 & NFPA 10 |
| | Ashastas Dragram | 6 Month | US EPA AHERA Plan |
| | Asbestos Program | 3 Year | US EPA AHERA Plan |
| FIRE MARSHAL | Fire Safety | 6 Month | A.C.A.§ 6-21-106 |
| | Fire Alarm | Annual | AFPC, Vol. 1, Table 901.6.1, & NFPA 72 |
| | Fire Sprinkler | Annual | AFPC, Vol. 1, Table 901.6.1, & NFPA 25 |
| | Fire Extinguisher | Annual | AFPC, Vol. 1, Section 906.2 & NFPA 10 |
| | Kitchen Suppression – Wet Chemical | 6 Month | AFPC, Vol. 1, Section 904.5-904.5.1 & NFPA 17A |
| | Kitchen Suppression – Dry Chemical | 6 Month | AFPC, Vol. 1, Section 904.6-904.6.1 & NFPA 17 |
| HEALTH DEPARTMENT | Natural Gas | Annual | A.C.A. 17-38- 201(a)(6)(A) |
| | Food Service | 6 Months | Food Establishment Regulations, Section 8- 401.10 page 165 |
| | Back-flow | Manufacturer's | Arkansas Plumbing |
| 1.4000 | Prevention | instructions | Code (2018) 312.10.1 |
| LABOR DEPARTMENT | Hot Water Boilers | HP - Annual LP External - Annual LP Internal - Year Unfired Pressure Vessel - 2 Year | A.C.A. § 20-23-203 |
| | Elevator | Annual | A.C.A. § 20-24- 112(a)(3)(A)(i) |
| ARKANSAS DEPARTMENT OF | Sewage Treatment | District staff check daily - | ADEQ policy – |
| ENVIRONMENTAL QUALITY | | 5 Years | NPDES 40-1-D-122.46 |
| | Fuel & Oil Tanks | 3 Year | APC&EC Regulation 40-CFR 280.35 (a)(1)(ii)(1)- Spill bucket testing and (2) Overfill device testing, 40 CFR 280.35 (a)(2)- Monthly walk through inspections: 40 CFR 280.36 |